

DESIGN FOR ACCESS AND MOBILITY NZS 41212001 ACCESS AND MOBILITY TOILETS

Disabled Toilet Facilities

10.5.6.1 Siting

The toilet pan should be sited so that:

(a) The front edge of the toilet seat shall be 700 – 750mm from the back wall

(f) The toilet lid is supported between 10deg and 15deg beyond the vertical to provide a back rest for the user

10.5.6.2 Height. The height of the top surface of the toilet pan shall be 460mm

10.5.6.4 Flushing Control. The flushing control shall be easy operable

Robertsons disabled toilet pans comply to the height and depth, and other dimennsional regulations as required.