

PERSONAL HYGIENE G1 AS1 2.4 BIDETS

2.4 Bidets

2.4.1 Bidets shall:

- a) Be firmly fixed in place, and**
- b) Have an impervious, easily cleaned surface finish (e.g. glazed earthenware or stainless steel), and**
- c) Be either over-rim feed type or submersible spray type, and**
- d) Satisfy the provisions of NZBC G12 for backflow prevention.**

Robertson Bidets comply to G1/AS1 2.4 when installed as per instructions. Check with local authority in regards to the need for High Hazzard Back Flow Protection