

PERSONAL HYGIENE G1.2.1 (WC PANS)

2.1.1 A WC system shall be firmly fixed in place and have:

- a) An impervious, easily cleaned surface finish (e.g. glazed earthenware or stainless steel),**
- b) Sufficient water trap volume to contain excreta from normal usage,**
- c) A minimum water seal depth of 50 mm**
- d) A pan which will not overflow during a single flush even if the outlet blocks,**
- e) A watertight flexible joint connecting the WC to a discharge pipe. The joint must be above floor level, and within the room containing the WC, and**
- f) A flushing apparatus capable of clearing all normal faecal matter from the pan in a single flush, and of delivering a full flush within 2 minutes of the previous usage.**

Robertsons toilet pans are manufactured to Watermark and WELS standards so meet or exceed Building code requirements.