

PERSONAL HYGIENE G1.2.2 (FLUSHING SYSTEMS)

2.2 Flushing systems

2.2.1 Flushing systems for sanitary fixtures shall use either cisterns or flushing valves.

2.2.2 Cisterns may be of the dual flush, 2 button type providing the choice of a full flush or a half flush

2.2.3 Flushing valves shall have backflow prevention complying with G12/AS1, and a water supply capable of supplying several flushes in

rapid succession. The capacity should be related to the nature and usage of the building

Robertsons toilet pans are manufactured to Watermark and WELS standards so meet or exceed Building code requirements.